

**OFFICE OF ASSISTANT ENGINEER,
P.H. SUB DIVISION, MAHNAR.**

Lt. No. 580 /Mahnar

Date:- 11 / 09 /2025

TO WHOM IT MAY CONCERN

This is to certify that S.D. Public School at Rampur Kitchini Desari Vaishali Bihar on the basis of inspection and Water Test Report (Attached) vide Lt. No. 03 Dt 11.09.2025 of Sub Divisional Lab PHED Mahnar, has safe drinking water facilities for the students and members of staff of the Institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State Govt.

This above is valid for a period of one Year.


Assistant Engineer
P.H. Sub Division Mahnar

Lab. No - 03

Dt. - 11.09.2025

Government of Bihar
P. H. SUB DIVISION, MAHNAR
Sub Divisional Water Testing Laboratory, MAHNAR
WATER QUALITY TEST REPORT

Zone - Muzaffarpur		District - Chapra (Saran)		Sub Division - Mahnar		Month/Year - Sept - 2025															
Sample collected on - 7/09/2025						& received in the laboratory on - 9/09/2025															
						Physico-Chemical & Bacteriological parameters															
						Turbidity (NTU)	pH	Conductivity (µS/cm)	T.D.S. (mg/L)	Total Hardness (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Fluoride (mg/L)	Nitrate (mg/L)	Iron (mg/L)	Total Alkalinity (mg/L)	Arsenic (mg/L)	Sulphate (mg/L)	Chloride (mg/L)	Bact.	
No.	Block	Panchayat	Village / Ward No.	Location Details/Name of Schemes	Type of source (HP, IM-HP, IM, HP/Ord./PW, Stand/PWS, House connection)	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	
00372	Dharampur	Rampur		3-D. Public School	Tap Water	0.8	7.2		140	126	44	15	-	0	0.1	189	-	15	88	Not	
Desirable limit						1.00	6.5-8.5	-	500	200	75	30	1	45	1.00	200	0.01	200	250	Positive/Negative	
Permissible limit in the absence of alternate source						5.00	No relaxation	-	2000	600	200	100	1.5	No relaxation	No relaxation	600	No relaxation	400	1000		

BIS: 10540:2012

NOTE: 1. Bold with underline or highlight the parameter if the result is beyond permissible limit.

2. BDL - Below Detection Limit

Remarks :-

Vaishali K. Sengupta
Lab Asst. 11/09/2025
Sub Divisional Lab, Mahnar
Hajipur, (Vaishali)

